Job Name/Location: Tag #: For: File Resubmit Date: PO No.: Approval Other GC: Architect: Mech: Engr: Rep:

(Project Manager)





LSN180HSV4

Multi F Standard 18,000 Btu/h Indoor Unit

Performance:

(Company)

Nominal Cooling Capacity (Btu/h) 18,000 Nominal Heating Capacity (Btu/h) 20,800

Cooling Nominal Test Conditions: Indoor: 80°F DB/67°F WB Outdoor: 95°F DB/75°F WB

Heating Nominal Test Conditions: Indoor: 70°F DB/60°F WB Outdoor: 47°F DB/43°F WB

Electrical:

Power Supply (V¹/Hz/Ø)	208-230/60/1
Rated Amps (A)	0.30

Pipe Connections:

Liquid (in, OD)	3/8
Vapor (in, OD)	5/8
Drain OD, ID (in)	13/16, 5/8
Temperature Sensor	Thermistor

Controls Features:

- •4-Way auto swing
- •24-Hour on/off timer
- Auto operation
- Auto restart
- Chaos wind
- •Inverter (variable speed fan)
- Jet Cool

- •3M HAF filter
- Self-cleaning indoor coil
- Sleep mode
- Condensate sensor connection
- Group control
- Smart AC module
- •Compatible with Single Zone HSV4 ODU

Included Accessories:

•Wireless Remote Controller - AKB73835312

Optional Accessories:

- LG Programmable Thermostat PREMTB10U
- Simple Controller with Mode (Black) PQRCVCL0Q
- Simple Controller with Mode (White) PQRCVCL0QW
- Simple Controller without Mode (Black) PQRCHCA0Q
- Simple Controller without Mode (White) PQRCHCA0QW
- AC Smart IV PACS4B000.ENCXLUS
- ACP IV PACP4B000.ENCXLUS
- LonWorks® Gateway PLNWKB100
- ACP IV BACnet® Gateway PQNFB17C1
- Dry Contact Unit (1 contact, 24 VAC external power) PQDSB1
- Dry Contact Unit (2 input, power from indoor unit) PQDSBC
- Dry Contacts for third party thermostat PQDSBNGCM1 or PDRYCB300

For a complete list of available accessories, contact your LG representative.

Entering Mixed Air:

Cooling (°F WB)	57-77
Heating (°F DB)	59-81

Unit Data:

R410A
EEV
37/33/28
Washable Pre-filter
3M HAF
31
36

Fan:

Туре	Cross Flow
Quantity	1
Motor/Drive	Brushless Digitally Controlled/Direct
Airflow Rate H/M/L (CFM) 572/501/434

Notes:

- 1.Acceptable operating voltage: 187V 253V.
- 2. Sound Pressure levels are tested in an anechoic chamber under ISO Standard 1996.
- 3. See Engineering Manual for sensible and latent capacities.
- 4.All power/communication cable to be minimum 18 AWG, 4-conductor, stranded, shielded and must comply with applicable local and national code.
- 5. Power wiring cable size must comply with the applicable local and national code.
- 6. This unit comes with a dry helium charge
- 7.Corresponding refrigerant piping length is in accordance with standard length of each outdoor unit and the level difference is 0 ft. All capacities are net with a combination ratio
- 8. Must follow installation instructions in the applicable LG installation manual.







LSN180HSV4 Multi F Standard 18,000 Btu/h Indoor Unit



Tag #:		
Date:		
PO No.:		

